

SPRINTER
26 A GAY LUSSAC

94430 CHENNEVIERES SUR MARNE
FRANCE

A l'attention de Marine BERNARD

Aix-en-Provence, le 18 / 06 / 2024

RAPPORT D'ESSAIS TEST REPORT

Page 1 / 3

Référence client Customer reference	BANNERSPRINT FLOOR 850
Référence du rapport Test report reference	AX24-02138.001 / DC24-02752
Bon de commande Order	

Les incertitudes de mesure ne sont pas prises en compte pour conclure sur la conformité des analyses sauf demande spécifique du client
Uncertainties are not taken into account to define compliance on analysis except specific customer request.



Jérôme VANNESSON
Directeur Technique
Technical Director

Tel. : +33 4 42 97 72 30
Fax :



(1) Test subcontracted in a SGS Laboratory. (2) Test subcontracted in a partner laboratory outside SGS group.
This document is issued by the Company under its General Conditions of Service available on request and accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.
Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.
Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only. This document shall not be reproduced, except in full, without prior written approval of the Company. It includes 3 page(s).

RAPPORT D'ESSAIS TEST REPORT

Page 2 / 3

Référence client Customer reference	BANNERSPRINT FLOOR 850
--	------------------------

-

Conclusion :

Par analogie avec les revêtements de sol résilient, textile ou stratifié, l'échantillon analysé témoigne d'un coefficient de friction au sens de la norme EN 13893 au delà de 0,30, assimilable à anti-dérapant.

By analogy with resilient, textile or laminate floor coverings, the tested sample shows a coefficient of friction referring to EN 13893 standard above 0.30, comparable to anti-slip.

Donneur d'ordre - Client	SPRINTER
Référence - Item n°	BANNERSPRINT FLOOR 850
Nombre d'échantillons Number of samples	1

(1) Test subcontracted in a SGS Laboratory. (2) Test subcontracted in a partner laboratory outside SGS group.

This document is issued by the Company under its General Conditions of Service available on request and accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only. This document shall not be reproduced, except in full, without prior written approval of the Company. It includes 3 page(s).

RAPPORT D'ESSAIS TEST REPORT

Page 3 / 3

 Référence client BANNERSPRINT FLOOR 850
 Customer reference

-

ANALYSE	METHODE	RESULTATS	UNITE	SPECIFICATIONS			Statut
				MINI	CIBLE	MAXI	
Essais sol / Flooring testings		Voir annexe / See appendix					

P : Pass ; F : Fail ; n.d : Not Detected

(1) Test subcontracted in a SGS Laboratory. (2) Test subcontracted in a partner laboratory outside SGS group.

This document is issued by the Company under its General Conditions of Service available on request and accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only. This document shall not be reproduced, except in full, without prior written approval of the Company. It includes 3 page(s).

Annexe / Appendix AX24-02138.001

I / Détermination du coefficient de frottement dynamique / Measurement of dynamic coefficient of friction

Conditions de test :

EN 13893 : 2002
Appareil utilisé : GMG 200
Nombre de mesures : 5 par condition, évaluation finale sur mesures #3 à #5
23 ± 2°C / 50 ± 5% humidité relative

Test conditions:

EN 13893: 2002
Device used: GMG 200
Number of measurements: 5 in each condition, final evaluation on measurements #3 to #5
23 ± 2 ° C / 50 ± 5% HR

Mesures Measurements	Coefficient de friction dynamique (μ) – Condition à sec Dynamic coefficient of friction (μ) - Dry condition	
	Sens long Length direction	Sens transverse Cross machine direction
#1	0,55	0,57
#2	0,57	0,55
#3	0,61	0,59
#4	0,56	0,57
#5	0,58	0,54
Moyenne #3 à #5 Average #3 to #5	0,58	0,57
Spécification Requirements	EN 14041:2004/AC:2006, clause 4.5 Slip resistance: μ ≥ 0,3*	
Conclusion	PASS - considéré comme anti-dérapant sous condition sèche PASS - considered as slip resistant under dry condition	
<p><i>*si ce sont des revêtements de sol résilients, textiles et stratifiés, avec un usage interne et/ou externe prévu, avec un coefficient de frottement dynamique de ≥ 0,30 lorsqu'ils sont testés sorti d'usine dans des conditions sèches conformément à la norme EN 13893, peuvent être déclarés comme classe technique DS.</i></p> <p>if resilient, textile and laminate floor coverings, with an internal and/or external intended use, and a dynamic coefficient of friction of ≥ 0,30 when tested ex-factory under dry conditions in accordance with EN 13893, can be declared as technical class DS.</p>		